


Fire Containment Insulation

Thermafiber® Safing™

- + Exceptional performance in Perimeter Fire Containment Systems
- + Provides life saving fire protection in rated assemblies
- + Fire resistant to temperatures above 2,000°F (1,093°C)
- + Easy to fabricate for through penetrations and firestopping
- + Conserves energy, reduces Greenhouse gas and carbon emissions
- + Resists moisture
- + Controls noise and sound



Up to
90%
Recycled
Content

LEED® Green Building Credits

Energy & Atmosphere	Materials & Resources	Indoor Environmental Quality	Innovation in Design
1	2.1, 2.2 3.1, 3.2 4.1, 4.2 5.1, 5.2	3.1, 3.2 9	1

Contributes to 33 LEED credits across 4 categories.



Since 1915

Tucker

W. L. TUCKER SUPPLY COMPANY, INC.

"The Best Names In Construction Are Under Our Roof!"

2800 Second St.
Cuyahoga Falls
OH 44221

WWW.WLTUCKER.COM

CALL: 330.928.2155

Thermafiber®
THE NAME IN MINERAL WOOL™



Made in the USA



Thermafiber Safing and FireSpan™ insulation provide the critical components of the perimeter fire containment system in the 111 South Wacker Building in Chicago, IL. Thermafiber insulation also contributed to the building's LEED® Gold Rating.



Thermafiber Safing is compression fitted between FireSpan insulation and the concrete slab edge to create a perimeter fire containment system.

Thermafiber® Safing

Description:

THERMAFIBER Safing products are designed to provide life saving fire protection in perimeter fire containment systems, floor and wall penetrations, construction joints, and other firestopping applications. These products are noncombustible, moisture-resistant, noncorrosive, nondeteriorating, mildew-proof and vermin-proof. Thermafiber Safing provides thermal insulation, fire protection, and acoustical control in many different UL and Intertek (formerly OPL) listed fire containment assemblies of 1, 2, and 3-hr ratings.

Product Options:

- Safing 4.0 pcf, 2" or greater thickness, is available with or without a vapor retarding foil facing.
 - Safing 6.0 pcf, 1.5" or greater thickness, is available with or without a vapor retarding foil facing.
 - Recycled Content Options¹:
 - Special "Green" Fiber 90%
 - EPA Choice Fiber (US Government Buildings)..... 75%
 - Standard Fiber 70%
- ¹Recycled content options other than standard must be specified at time of order.

Installation:

- All firestopping insulation should be installed per the architectural specification or system specific test description. All compressed Safing insulation should be installed per the listed assembly.
- Perimeter Installation: Safing insulation should be compression fitted between the slab edge and the FireSpan curtain wall insulation, leaving no voids.
 - Penetration Application: Safing insulation should be cut slightly larger than the opening and compression fitted into the opening, leaving no voids.
 - Construction Joint Application: Safing insulation should be compression fitted into the joint opening, leaving no voids.

Standard Sizes:

	Thickness*	Widths**	Lengths**
Safing 4.0 pcf	1"- 6"	16", 24", 36"	48", 60"
Safing 6.0 pcf	1"- 6"	16", 24", 36"	48", 60"
Tolerances	+1/4" - 1/8"	±1/8"	±1/2"

*Thicknesses are available in 1/2" increments. **Custom sizes are available upon request.

Technical Data:

Product Designation	Actual Density	Tested to ASTM C 518		Tested to ASTM E 84			
		"k" @ 75° [24°C] BTU.in/hr.sq. ft. °F	"R" value per inch of thickness***	Unfaced	Foil Faced		
Safing	4.0 pcf	0.24	'R' = 4.2	Flame Spread 0	Smoke Developed 0	Flame Spread 25	Smoke Developed 0
Safing	6.0 pcf	0.24	'R' = 4.2	Flame Spread 0	Smoke Developed 0	Flame Spread 25	Smoke Developed 0

***R = thickness divided by 'k'

Fire-Containment Tests Per ASTM E 2307

Safing insulation is a critical component of any perimeter fire containment system. Thermafiber has performed decades of testing in all of the containment systems listed below. For more complete test information, see SA707, THERMAFIBER Life-Safety Fire Containment Systems technical catalog or UL and Intertek (formerly OPL) Directories. For a full listing of containment systems visit www.thermafiber.com and click on Fire Rated Assemblies. UL Reference = TYPE SAF

- Aluminum Spandrel Curtain Wall Fire Containment
- Steel Stud-Framed/Gypsum Sheathing Curtain Wall Fire Containment
- Glass Spandrel Curtain Wall Fire Containment
- Granite Spandrel Curtain Wall Fire Containment
- Precast Concrete Spandrel

Standards Compliance:

Safing Insulation meets the following:	
ASTM C 665	Non-corrosive, Type I, III
ASTM C 612	Type IA, IB, II
ASTM E 136	Rated Non-combustible per NFPA Standard 220
ASTM E 96	Unfaced, 50 Perms as tested
ASTM E 96	Foil Faced, 0.02 Perms as tested
ASTM C 1104	Absorbs less than 1% by volume
ASTM E 814 or UL 1479	Safing Insulation used in conjunction with an approved fill, void, or cavity material sealant or other approved material in through – penetration firestop systems.
UL 2079	Safing Insulation used in conjunction with an approved fill, void or cavity material in construction joint systems

Safing products are approved by: **New York City Board of Standards & Appeals** – (under BSA 39-74-SM & accepted by MEA-209-82-M, Vol. 4).

Thermafiber Insolutions®:

Thermafiber offers industry leading technical and engineering assistance to architects, specifiers, and contractors. These services include CAD drawings, engineering judgments, LEED® Credit Information, product recommendations, and customized products. Contact our technical services department at 1-888-834-2371, or email technicalservices@thermafiber.com.

For Further Information:

For additional information about these or other Thermafiber products contact us at 1-888-834-2371 or visit our website www.thermafiber.com.

Notice:

THERMAFIBER, Inc. shall not be liable for incidental and consequential damages, directly or indirectly sustained, nor for any loss caused by application of these goods not in accordance with current printed instructions or for other than the intended use. THERMAFIBER liability is expressly limited to replacement of defective goods. Any claim shall be deemed waived unless made in writing within thirty (30) days from date it was or reasonably should have been discovered.

Submittal Approvals:



Job Name	
Contractor	Date